

UNIVERSITÀ DEGLI STUDI DI PADOVA

DIPARTIMENTO DI INGEGNERIA CIVILE, EDILE E AMBIENTALE

Laboratorio Sperimentale per le Prove sui Materiali da Costruzione

DEPARTMENT OF CIVIL, ENVIRONMENTAL AND ARCHITECTURAL ENGINEERING

Building materials testing Laboratory

Sede: via Marzolo n. 11/A - 35131 PADOVA

Segreteria: +39.049.827.5607

Fax: +39.049.827.5587 e-mail: lab.materiali@dicea.unipd.it

TEST REPORT N. 35378

Page 1/2

Applicant: Eterno Ivica S.r.I., via Austria Z.I. n. 25/E - Padova

Application: Received at 22/01/2013

Material: 3 samples of pedestal "NEW-MAXI NM5" series, received at 22/01/2013

Required test: Measure the maximum compressive eccentric load of the specimen and the

displacement of the testing machine's crossbar.

Testing method: The compression tests were made for all the 3 samples. The components of the

pedestal had been assembled and the four tabs removed, the height of pedestal was

regulated to the medium (210.0 mm) stroke of the screw.

Testing speed set to 10 mm/min (checking movement of moving crossbar of the

universal testing machine Galdabini, type Sun/60, with a load capacity of 600 kN).

The load applied with hardened steel plate on the base of specimen and a steel

rectangular prism on the top of the pedestal with an eccentricity of 27.5 mm. The values of maximum load (F_{max}) are the values of load at first failure/rupture.

The testing machine's certificate of calibration is n°020-13F about Calibration centre LAT

n° 34 with due data January 15th, 2014.

Test activities were carried out on April 3rd, 2013.

For any technical and dimensional detail, assembling scheme and any other information not included in this document, brochures and technical data sheets are at Applicant's

disposal.

Test Result

Specimen	Max Load F _{max} [kN]	Stroke at F _{max} [mm]
1	19.07	6.3
2	19.29	6.5
3	18.31	6.2

Padova, May 2nd, 2013

Laboratory Chief (Prof. Claudio Modena)

Department Chief (Prof. Carmelo Majorana)



UNIVERSITÀ DEGLI STUDI DI PADOVA

DIPARTIMENTO DI INGEGNERIA CIVILE, EDILE E AMBIENTALE

Laboratorio Sperimentale per le Prove sui Materiali da Costruzione DEPARTMENT OF CIVIL, ENVIRONMENTAL AND ARCHITECTURAL ENGINEERING

Building materials testing Laboratory

Sede: via Marzolo n. 11/A - 35131 PADOVA Segreteria: +39.049.827.5607

Fax: +39.049.827.5587 e-mail: lab.materiali@dicea.unipd.it

TEST REPORT N. 35378

Page 2/2




Figure 1 Diagram force versus displacement of testing machine's crossbar for "NEW-MAXI NM5" specimen.



Figure 2 typical "New-Maxi NM5" specimen.

Padova, May 2nd, 2013

Laboratory Chief (Prof. Claudio Modena)

Department Chief (Prof. Carmelo Majorana)

The results refer to the samples tested. This report cannot be reproduced without explicit authorization from the Building materials testing Laboratory and it isn't a product certification.